

differential relay

{ no coordination
only one equipment




$$\text{bias} : \frac{|I_1 + I_2|}{2}$$

{ N : bias winding
analog

$$\text{diff} : \begin{cases} |I_1 - I_2| \checkmark \\ |I_1| - |I_2| \\ |\angle I_1 - \angle I_2| \end{cases}$$

← the various type of differential relays




CT Saturation :


I_{aut}
 $\left\{ \begin{array}{l} \text{out of protection zone:} \\ \text{in the protection zone:} \end{array} \right.$
 $\left\{ \begin{array}{l} \text{bias prevents from sending trip} \\ i_{bias} \times \\ i_{diff} \checkmark \end{array} \right.$

transmission line current \Rightarrow

ϕ, i : sinusoidal



modeling of CT saturation:




in saturation condition,

i_{bias} , i_{diff} is calculated.

respect to trip graph of differential

relay, it is determined that the relay

send a trip or not.



during saturation, voltage is equal to zero


maximum error is when ($v=0$). (time $\approx 3 \text{ ms}$)

(it is enough to send
 a trip (operating time
 of differential relay
 is instantaneous)

data communication : (smart grid)


the most important issue is reliability.

private network




goal : { decreasing the number of signals \Rightarrow
 reliability rising

Sumation transformer



inrush current:

1) saturation



2) $v = N \frac{d\phi}{dt} \Rightarrow \phi = \frac{1}{N} \int v dt$

